

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1591:138 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models LSS4, LSS4/12 LSS4/36 and LSS4/52 control units. Local, auxiliary, remote station and proprietary or central station service; non-coded, coded, marchtime, manual, automatic, releasing device, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed. This listing includes the following modules:

| | | | | |
|------|-------|-------|-------|-------|
| 4CLA | 4REXP | MBPR | 4ZEXP | 8ZEXP |
| RMOD | 4IAC | LSSPS | | |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-1102:113 and 7165-1388:105

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JANUARY 16, 2003

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager